

TESTING ACTIVE FILTERS AND ACHIEVING MAXIMUM EFFICIENCY

**Luis Rudenas, Active Ventilation Engineer
Andrew Mc Gregor, Active Filtration Testing Officer
James Stephanou, University of Wollongong Graduate**

**Australian Nuclear Science Technology Organization
Lucas Heights, Sydney, Australia**



Overview

- ANSTO conducts active ventilation filter testing throughout the organisation as part of its licensing agreement with the governing body ARPANSA (Australian Radiation Protection And Nuclear Safety Agency).
- Testing is performed on a regular basis. Once the test is completed a determination is made as to when the filter will require a change.




Overview

ANSTO collaborates with a range of facilities, some of these facilities that require testing include:


- OPAL Nuclear Reactor
- Australian Nuclear Medicine Facility
- ANSTO Waste Facility
- Australian Radio Pharmaceuticals
- National Medical Cyclotron (RPA Hospital)
- University Of Queensland Cyclotron
- Macquarie University



Ventilation on the Cyclotron, Labs, Workshops, Hot Cells & Fume Cupboards



Cyclotron Target.



Hot cells being checked.

Filter testing preparation and process

1. Installation of injection and sampling testing points.
2. Installation of parallel canisters for carbon analysis.
3. Aerosol Uniformity Tests (if more than 1 filter is installed).
4. Checking & changing pre-filters at each test on a yearly basis.
5. Checking the flow rates of the filter banks.
6. Check the Pressure Drop across the HEPA filters and prefilters.



Filter testing preparation and process

7. Measure HEPA Filters with a particulate aerosol upstream and downstream. Penetration of particles to assess the overall filter system efficiency.
8. Measuring Carbon filters with a gas upstream and downstream to assess the mechanical efficiency of the filters.
9. Carbon analysis (Sample sent to USA for lab testing).
10. Maintenance of filter banks.
11. Report generating.




Standards for assembling and testing filters

The following standards are adhered to when testing and assembling filters:

- ASME AG-1 Code on Nuclear Air and Gas Treatment
- ASTM 3803-89 Standard Test Method of Nuclear-Grade Activated Carbon
- ASME N509 Nuclear Power Plant Air-Cleaning Units & Components
- ASME N510 Testing of Nuclear Air-Treatment Systems
- ASME N511 In-Service Testing of Nuclear Air Treatment Systems



HEPA Filter & Carbon Bank



Response to test results

HEPA Filters.

- Requires to pass the mechanical efficiency test at 0.03% maximum penetration for 0.3 microns particles. The HEPA Filters are changed if the static pressure is twice the value on installation.



Response to test results

Carbon Filters.

- Required to pass a Mechanical Efficiency test with a gas at 1% penetration & to pass the ASTM 3803-89 test for the carbon itself.
- If a Mechanical test failure is noted (seal failure or structural damage) to the filter, the filters are to be replaced, reinstalled or if possible repaired.



Response to test results

Carbon Filters.

- Following the standard ASTM 3803-89 a penetration level of Methyl-iodine is agreed with the Operator for carbon filter replacement. At 1% penetration an action plan should be started.
- The carbon used to refurbish the filters requires a valid ASTM 3803-89 Certificate (5 years)
- Spare filters also require a valid test certificate (5 years of validity if never used)



Copper testing manifold



INTERNATIONAL SOCIETY FOR NUCLEAR
AIR TREATMENT TECHNOLOGIES

36th Nuclear Air Cleaning Conference

· June 28 – 29, 2022 · Salt Lake City, UT ·



Injection and Testing in Metal/Plastic


Injection point. Pop-rivets in metal ducts



Injection point. Tech Screws in plastic ducts



100 % manifolds in two filters



Downstream of the fan 1 *T testing point.

90 degrees Air Flow Checks



Filter changing Process

If a filter change is required:

- The area must be classed as a “**Blue**” radiation area.
- Health physics support is required to check the area and filters.
- The Technicians must wear appropriate PPE, including **coveralls, overshoes, Gloves and P3 masks.**
- Old filters must be bagged and disposed of or refurbished.



Filter changing Process



This work is often conducted in hot conditions and access is often very restrictive.



Prefilters & HEPA Filters Changed at the CAI

Prefilters are changed every year

HEPA Filters change on test failure or static pressure increase.




Carbon & HEPA Filter Mechanical Efficiency Tests Only

HEPA Filter



Carbon Filter



Carbon & HEPA Filter Mechanical Efficiency Tests Only

HEPA Upstream
100% Concentration.



Carbon Upstream in
ppm of 1-Bromobutane




Penetration = 100 X
(Conc. down/Conc.
Upstream)

HEPA Downstream
penetration



Carbon Downstream in
ppm of 1-Bromobutane



Carbon Maximum
P = 1 % of 1-
Bromobutane

HEPA maximum
P = 0.03 %

PAO Emery 2004

HEPA Filter Tests Results at CAI Queensland

Table 1. HEPA Filter penetration test results. Maximum allowed 0.03 %

	Cyclotron Vault	Hot Cell Exhaust	Radio-chem Exhaust	Cyclotron Workshop	Hot Lab Research	Shielded Fume Hood	Fume Cup. EF-1-2	Hot Lab GMP	Radio-chem Exh. Arms	Fume Cup. FC 2-2	Fume Cup. FC 2-3
	HF-EF 1-11	HF-EF2-6	HF-EF2-3	HF-EF-1-10	HF-EF-2-2	HF-EF-2-7	HF-EF1-2	HF-EF-2-1	HF-EF-2-8	HF-FEF-2-2	HF-FEF-2-3
2022 Pen %	0	0	0	0	0	0	0	0	0	0	0
2021 Pen %	0	0	0	0	0	0	0	0	0	0	0
2020 Pen %	0	0	0	0	0	0	0	0	0	0	0
2019 Pen %	0	0	0	0.004	0	0	0	0	0.001	0	0
2018 Pen %	0	0	0	0	0	0	0	0	0	0	0
2017 Pen %	0.004	0.001	0	0	0.02	0.001	0	0.01	0.002	0.004	0.01
2016 Pen. %	0.006	0.02	0.005	0	0.014	0	0.005	0.007	0	0.001	0
2015 Pen %	0	0	0	0	0.013	0	0	0	0	0	0
2014 Pen %	0	0	0	0							
2013 Pen %	0	0	0	0							

HEPA Filters Static Pressure at the CAI Queensland

Table 2. HEPA Filter Static Pressure test results.

	Cyclotron	Hot Cell	Radio-chem	Cyclotron	Hot Lab	Shielded	Fume Cup.	Hot Lab	Radio-chem	Fume Cup.	Fume Cup.
	Vault	Exhaust	Exhaust	Workshop	Research	Fume Hood	EF-1-2	GMP	Exh. Arms	FC 2-2	FC 2-3
	HF-EF 1-11	HF-EF2-6	HF-EF2-3	HF-EF-1-10	HF-EF-2-2	HF-EF-2-7	HF-EF1-2	HF-EF-2-1	HF-EF-2-8	HF-FEF-2-2	HF-FEF-2-3
2022 Pressure	75	45	100	180	155	75	55	250	25	150	110
2021 Pressure	50	25	100	155	125	75	50	270	25	140	100
2019 Pressure	75	48	100	140	150	100	52	260	60	140	125
2018 Pressure	75	48	130	270	160	100	50	250	25	150	150
2017 Pressure	78	48	125	300	150	100	50	210	25	130	125
2016 Pressure	52	27	77	325	140	100	55	200	10	126	125




Mk III Canisters Installation CAI




Canister Box- CAI- Mark III

Vel Sampling = +/- 10% Vel Filter



Six Mark III canisters installed in CAI



Mark III Canisters installed in CAI



Velocity and pressure testing upstream point

Velocity and pressure testing downstream point



Mechanical Efficiency of Carbon Filters

CAI University of Queensland

Table 3. Carbon Filters Mechanical Efficiency results. Maximum allowed penetration 1%

	Cyclotron Vault		Hot Cell Exhaust		EF1-11 Total (%)	EF2-6 Total (%)
	EF1-11	EF1-11	EF2-6	EF2-6		
	First Filter	2nd Filter	First Filter	2nd Filter		
2022 Pen %	0	0	0	0	0	0
2021 Pen %	0	0	0	0	0	0
2020 Pen %	0	0.1	0.0067	0.21	0.1	0.3167
2019 Pen %	0	0.015	0.004	0	0.015	0.0040
2018 Pen %	0.198	0	0.058	0	0.198	0.0580
2017 Pen %	0.09	0	0.018	0	0.090	0.018
2016 Pen %	0.068	0	0.01	0	0.068	0.01
2015 Pen %	0	0	0.016	0	0	0
2014 Pen %	0	0.09	0	0.006	0.09	0.006
2013 Pen %	0	0.09	0	0.006	0.09	0.006





Carbon Filters Test to ASTM 3803-89

Table 4. Carbon ASTM 3803-89 Tests **Maximum Recommended 1% penetration**

	EF 1-11 First		EF 1-11 2nd		EF2-6 First		EF2-6 Second	
2022 Pen %	0.7	(+/- 0.006)	No Sample		1.116	(+/- 0.008)	No Sample	
2021 Pen %	0.062	(+/- 0.001)	0.062	(+/- 0.001)	0.445	(+/- 0.005)	0.882	(+/-0.008)
Carbon Certificates	0.062	(+/- 0.001)	0.062	(+/- 0.001)	No Sample		No Sample	
Lot/Batch	48/105		48/105		No Sample		No Sample	
2020 Pen %	1.131	(+/- 0.007)	No Sample		0.217	(+/- 0.003)	No Sample	
2019 Pen %	0.13	(+/- 0.002)	9.307		0.13	(+/- 0.002)	0.939	(+/- 0.012)
Carbon Certificates	0.13		0.57		0.13		0.57	
Lot/Batch	48/94		72/03		48/94		72/03	
2018 Pen %	1.118	(+/- 0.014)	No Sample		0.53	(+/- 0.010)	No Sample	
2017 Pen %	1.015	(+/- 0.008)	No Sample		0.368		No Sample	
2016 Pen %	0.371		No Sample		0.359		No Sample	



Methyl-Iodine Penetration (%)



Conclusions

Correctly design new filter housings with canisters, testing manifolds and bubble tight dampers.

Change prefilters at least in annual base to keep clean the HEPA Filters.

Periodically test the HEPA and carbon filters and be prepared for filter changes at any time.

Keep a trend of pressure increases through HEPA filters.



Any Questions ?



ANSTO Contact:

Luis Rudenas

Active Ventilation Engineer

lrx@ansto.gov.au

Phone : 01161297173982

Mobile: 011612418288013

